

ENA EREC G98/1-4:2019

Type Approval and Manufacturer declaration of compliance with the requirements of G98.

This form should be used when making a Type Test submission to the Energy Networks Association (ENA).

If the Micro-generator is Fully Type Tested and already registered with the ENA Type Test Verification Report Register, the Installation Document should include the Manufacturer's Reference Number (the Product ID), and this form does not need to be submitted.

Where the Micro-generator is not registered with the ENA Type Test Verification Report Register this form needs to be completed and provided to the DNO, to confirm that the Microgenerator has been tested to satisfy the requirements of this EREC G98.

SSEG Type		Photovoltaic	Photovoltaic Microinverter				
System Sup	plier name	Hoymiles P	ower Electronic	es Inc.			
Address		No.18 Kang P.R. China	jing road, Hangz	Zhou, Zhejiang Province,			
Tel	+86 571 28056101		Fax	+86 571 28056137			
E:mail	zhangxingyao@hzo m	converter.co	Web site	www.hoymiles.com			
Maximum rated	Connection Option						
capacity, use	0.8/0.7/0.6	kW single pł	hase, single, split or three phase system				
separate sheet if	NA	kW three ph	ase				
more than one	NA	kW two phas	ses in three pha	se system			
connection option.	NA	kW two phases split phase system					


Manufacturer Type Test declaration. - I certify that all products supplied by the company with the above Type Tested reference number will be manufactured and tested to ensure that they perform as stated in this document, prior to shipment to site and that no site modifications are required to ensure that the product meets all the requirements of EREC G98.

Signed	张芝雄	On behalf of	Hoymiles Power Electronics Inc.
--------	-----	--------------	---------------------------------


H hoymiles #15

Note that testing can be done by the Manufacturer of an individual component or by an external test house.


Where parts of the testing are carried out by persons or organisations other than the Manufacturer then that person or organisation shall keep copies of all test records and results supplied to them to verify that the testing has been carried out by people with sufficient technical competency to carry out the tests.
















Power	Power Quality – Harmonics: These tests should be carried out as specified in BS EN 61000-3-2.									
SSI	EG rating per pl		*0.00/11							
Harmo nic	At 45-55% o	f rated output	100% of ra	ated output	IN V=IVI V	*3.68/rpp				
	Measured Value(MV) in Amps	Normalised Value (NV) In Amps	Measured Value(MV) In Amps	Normalised Value (NV) In Amps	Limit in BS EN 61000-3- 2 in Amps	Higher limit for odd harmonic s 21 and above				
2	0.0745	0.4578	0.1490	0.8480	1.080					
3	0.0218	0.1360	0.0536	0.2204	2.300					
4	0.0119	0.0715	0.0288	0.0695	0.430					
5	0.0079	0.0487	0.0209	0.0387	1.140					
6	0.0070	0.0447	0.0169	0.0387	0.300					
7	0.0070	0.0397	0.0139	0.0258	0.770					
8	0.0060	0.0338	0.0119	0.0209	0.230					
9	0.0040	0.0258	0.0109	0.0129	0.400					
10	0.0040	0.0228	0.0089	0.0209	0.184					
11	0.0040	0.0218	0.0089	0.0179	0.450					
12	0.0040	0.0209	0.0079	0.0149	0.153					

H hoymiles The

13	0.0040	0.0228	0.0070	0.0179	0.210	
14	0.0030	0.0159	0.0079	0.0129	0.131	
15	0.0020	0.0119	0.0099	0.0238	0.150	
16	0.0020	0.0119	0.0060	0.0079	0.115	
17	0.0020	0.0119	0.0089	0.0129	0.132	
18	0.0020	0.0139	0.0109	0.0149	0.102	
19	0.0010	0.0070	0.0030	0.0179	0.118	
20	0.0010	0.0040	0.0040	0.0129	0.092	
21	0.0020	0.0099	0.0050	0.0010	0.107	
22	0.0020	0.0099	0.0030	0.0179	0.084	
23	0.0030	0.0199	0.0030	0.0070	0.098	0.147
24	0.0030	0.0189	0.0020	0.0070	0.077	
25	0.0020	0.0119	0.0060	0.0079	0.090	0.135
26	0.0020	0.0119	0.0030	0.0010	0.071	
27	0.0020	0.0129	0.0030	0.0179	0.083	0.124
28	0.0020	0.0109	0.0030	0.0179	0.066	
29	0.0020	0.0149	0.0030	0.0139	0.078	0.117
30	0.0010	0.0079	0.0030	0.0149	0.061	
31	0.0020	0.0149	0.0040	0.0119	0.073	0.109
32	0.0010	0.0060	0.0040	0.0010	0.058	
33	0.0010	0.0089	0.0030	0.0209	0.068	0.102
34	0.0010	0.0040	0.0030	0.0070	0.054	
35	0.0030	0.0159	0.0030	0.0139	0.064	0.096
36	0.0030	0.0189	0.0000	0.0149	0.051	
37	0.0020	0.0109	0.0030	0.0050	0.061	0.091
38	0.0000	0.0020	0.0030	0.0099	0.048	
39	0.0010	0.0060	0.0030	0.0050	0.058	0.087
		•		·		



40	0.0010	0.0060	0.0010	0.0179	0.046	
	0	or odd harmonio ner limits are uti		•		

part 6.2.3.4 of BS EN 61000-3-2 in the box below.

Power Quality. Voltage fluctuations and Flicker.									
		Starting			Stopping	J	Rur	nning	
	dmax [%]	dc [%]	d(t) [%]	dmax [%]	dc [%]	d(t) [%]	Pst	Plt 2 hours	
Measured Values	0.36	0.3	0	0.36	0.3	0	0.133	0.058	
Normalised to standard impedance and 3.68kW for multiple units	2.21	1.84	0	2.21	1.84	0	0.82	0.36	
Limits set under BS EN 61000-3-2	4%	3.30%	3.3% 500ms	4%	3.30%	3.3% 500ms	1	0.65	
Test start date	2020-07-31 Test end date 2020-07-31								
Test location					INSPEC QUIPME				

Power quality – DC injection: This test should be carried out in accordance with EN 50438 Annex D.3.10							
Test power level	20%	50%	75%	100%			
Recorded value(mA)	0.016	0.056	0.875	2.952			
as % of rated AC	0.004%	0.004%	0.025%	0.085%			
Limit	0.25%	0.25%	0.25%	0.25%			

Power Quality – **Power factor:** This test shall be carried out in accordance with EN 50538 Annex D.3.4.1 but with nominal voltage -6% and +10%. Voltage to be maintained within ±1.5% of the stated level during the test.



	216.2V	230V	253V
20% of Registered	0.9887	0.9874	0.9887
50% of Registered	0.9953	0.9946	0.9936
75% of Registered	0.9967	0.9955	0.9948
100% of Registered	0.9975	0.9963	0.9959
Limit	>0.95	>0.95	>0.95

Protection. Frequency tests These tests should be carried out in accordance with EN 50438 Annex D.2.4 and the notes in EREC G98 Annex A1 A 1.3.2 (Inverter connected) or Annex A2 A.2.2.2 (Synchronous)

Function	Setti	ng	Trip test		"No trip tests"	
	Frequency	Time delay	Frequency	Time delay	Frequency /time	Confirm no trip
U/F stage 1	47.5Hz	20s	47.5Hz	20s	47.7Hz/ 30s	Confirmed
U/F stage 2	47Hz	0.5s	47Hz	0.54s	47.2Hz/ 19.5s	Confirmed
					46.8Hz/ 0.45s	Confirmed
O/F stage 2	52Hz	0.5s	52Hz	0.53s	51.8Hz/ 120s	Confirmed
					52.2Hz/ 0.45s	Confirmed

Protection. Voltage tests These tests should be carried out in accordance with EN 50438 Annex D.2.3 and the notes in EREC G98 Annex A1 A 1.3.1 (Inverter connected) or Annex A2 A.2.2.1 (Synchronous)

Function	Setti	ng	Trip test		"No trip tests"	
	Voltage	Time delay	Voltage	Time delay	Voltage /time	Confirm no trip
U/V stage 2	184V	2.5s	183.4V	2.52s	188V/5.0s	Confirmed
					180V/2.45s	Confirmed
O/V stage 1	262.2V	1.0s	262.8V	1.02s	258.2V/5.0s	Confirmed
O/V stage 2	273.7V	0.5s	274.4V	0.53s	269.7V/0.95s	Confirmed



277.7V/0.45s Confirmed

Note for Voltage tests the Voltage required to trip is the setting ± 3.45 V. The time delay can be measured at a larger deviation than the minimum required to operate the protection. The No trip tests need to be carried out at the setting ± 4 V and for the relevant times as shown in the table above to ensure that the protection will not trip in error.

Protection. Loss of Mains test. For PV Inverters shall be tested in accordance with BS

EN62116. Other Inverters should be tested in accordance with EN 50438 Annex D.2.5

at 10%,55% and 100% of rated power.

Note: Inverter tested according to BS EN 62116.

Test Power and imbalance	33%	66%	100%	33%	66%	100%
	-5% Q	-5% Q	-5% P	+5% Q	+5% Q	+5% P
Trip time. Limit is 0.5s	45.13ms	411.2ms	325.2ms	57.23ms	411.5ms	336.5ms

Protection. Frequency change, Stability test This test should be carried out in accordance with EREC G98 Annex A1 A 1.3.5 (Inverter connected) or Annex A2 A.2.2.5 (Synchronous).

	Start Frequency	Change	End Frequency	Confirm no trip
Positive Vector Shift	49Hz	+50 degrees		Confirmed
Negative Vector Shift	50Hz	- 50degrees		Confirmed

Protection – **Frequency change, RoCoF Stability test:** The requirement is specified in section 11.3, test procedure in Annex A 1.3.5 (Inverter connected) or Annex A2 A.2.2.5 (Synchronous).

	Ramp range	Test frequency	Test Duration	Confirm no trip
Positive Frequency drift	49Hz to 51Hz	+0.95Hz/sec	2.1s	Confirmed
Negative Frequency drift	51Hz to 49Hz	-0.95Hz/sec	2.1s	Confirmed

Protection – Limited Frequency Sensitive Mode – Overfrequency test: This test						
should be carrie	should be carried out in accordance with EN 50438 Annex D.3.3 Power response to					
over- frequency	over- frequency. The test should be carried out using the specific threshold frequency of					
50.4 Hz and dro	50.4 Hz and dro op of 10%.					
Test sequence	Measured	Frequency	Primary Power	Active Power		
at Registered	Active Power		Source	Gradient		
Capacity >80%	Output					
Step a) 50.00	800.3W	50Hz		-		



Hz ±0.01Hz				
Step b) 50.45	700.014/	50.45Hz		-
Hz ±0.05Hz	790.9W			
Step c) 50.70	750.1W	50.7Hz		-
Hz ±0.10Hz	750.177			
Step d) 51.15	678.3W	51.15Hz		-
Hz ±0.05 Hz	070.300			
Step e) 50.70	751.2W	50.7Hz		-
Hz ±0.10Hz	751.200			
Step f) 50.45	791.1W	50.45Hz		-
Hz ±0.05Hz	791.100			
Step g) 50.00	900 114/	50Hz		-
Hz ±0.10Hz	800.1W			
Test sequence	Measured	Frequency	Primary Power	Active Power
at Registered	Active Power		Source	Gradient
Capacity	Output			
40% - 60%				
Step a) 50.00	406.7W	50Hz		-
Hz ±0.01Hz	400.7 W			
Step b) 50.45	399.1W	50.45Hz		-
Hz ±0.05Hz	399.100			
Step c) 50.70	382.5W	50.7Hz		-
Hz ±0.10Hz	302.377			
Step d) 51.15	346.7W	51.15Hz		-
Hz ±0.05 Hz	340.7 W			
Step e) 50.70	381.4W	50.7Hz		-
Hz ±0.10Hz	301.477			
Step f) 50.45	398.6W	50.45Hz		-
Hz ±0.05Hz	390.000			
Step g) 50.00	406.9W	50Hz		-
Hz ±0.10Hz	400.977			
Steps as define	ed in EN 50438			

Protection – Power output with falling frequency test: This test should be carried out in accordance with EN 50438 Annex D.3.2 active power feed -in at under-frequency.					
Test sequence	Measured Active	Frequency	Primary power		
	Power Output		source		
Test a) 50 Hz ± 0.01 Hz	800.13W	50Hz	DC Supply		
Test b) Point between 49.5 Hz and 49.6 Hz	800.08W	49.55Hz	DC Supply		
Test c) Point between 47.5 Hz and 47.6 Hz	800.02W	47.55Hz	DC Supply		
NOTE: The operating point in Test (b) and (c) shall be maintained for at least 5 minutes			or at least 5 minutes		

Protection. Re-connection timer.					
Test should prove that the reconnection sequence starts after a minimum delay of 20 s for restoration of voltage and frequency to within the stage 1 settings of Table 2.					
Time delay setting	Measured delay	No reconnection when voltage or frequency is brought to just outside stage 1 limits of table 1.			
20.0s	30.0s	At 266.2V	At 180V	At 47.4Hz	At 52.1Hz
Confirmation that the SSEG does not re-connect.		Confirmed	Confirmed	Confirmed	Confirmed

Fault level contribution. The requirement is specified in section 5.7, test procedure in Annex A or B 1.4.6

For a directly coupled SSEG		For a Inverter SSEG			
Parameter	Symbol	Value	Time after fault	Volts	Amps
Peak Short Circuit current	ip	N/A	20ms	19.25V	0.153A
Initial Value of aperiodic	А	N/A	100ms	10.26V	0.121A
Initial symmetrical	lk	N/A	250ms	9.24V	0.116A
Decaying (aperiodic)	iDC	N/A	500ms	5.98V	0.109A
Reactance/Re sistance Ratio	X/R	N/A	Time to trip	0.0032	(in seconds)

Self-Monitoring solid state switching :No specified test requirements. Refer to EREC G98 Annex A1 A 1.4.6 (Inverter connected).	Yes/or NA
It has been verified that in the event of the solid state switching device failing to disconnect the Micro-generator, the voltage on the output side of the switching device is reduced to a value below 50 V within 0.5 s.	N/A

Logic interface (input port)	Yes/or NA	
Confirm that an input port is provided and can be used to shut down the	Vee	
module.	Yes	

Additional comments

